

## 1333 NW Eastman Parkway, Gresham, Oregon 97030-3813 Phone 503-618-2355 • Fax 503-666-8330 GreshamOregon.gov/fire GFD@GreshamOregon.gov

**CHECK SHEET FOR TEST OF EMERGENCY LIGHTING SYSTEMS** 

Da	ate of Service:	<del></del>	
Name of Building			
Address/City/Zip of Building			
Phone #			
ANI	NUAL INSPECTION	N AND TEST	
EXIT SIGNS	PER STANDARDS	N/A	MAINTENANCE REQUIRED
EXIT SIGN (Housing)			
Undamaged (housing, glazing), secure mounting bracket, guards in place (optional), AC – power pilot lamp (on)			
EXIT SIGN (Lamps)			
Undamaged, unobstructed, illuminated, correct arrow illuminated (left, right), broken lamp, no continuity			
EXIT SIGN (Battery /IES)			
Corrosion, dirty			
EXIT SIGN (Wires, Terminals,			
Connectors)			
Wire insulation cracked, bare wires, loose terminal or connector			
EXIT SIGN - 90 Minute Test			
Failure, test battery, test transformer, test printed circuit board			

EMERGENCY LIGHTING	PER	N/A	MAINTENANCE
	STANDARDS		REQUIRED
EMERGENCY LIGHT (Housing)			
Undamaged, secure mounting bracket, AC – power pilot lamp (on), corrosion, dirty			
EMERGENCY LIGHT (Lamps)			
Undamaged, unobstructed, lamps aimed properly, broken lamp, no continuity			
EMERGENCY LIGHT (Battery / IES)			
Corrosion, dirty			
EMERGENCY LIGHT (Wires			
Terminals, Connectors)			
Wire insulation cracked, bare wires, loose terminal, loose connector			
EMERGENCY Light – 90 Minute Test			
Failure, test battery, test transformer, test printed circuit board			
NUMBER OF UNITS TESTED			
Exit Lights Emerge	ency Lights	Con	nbo's
RECOMMENDATIONS AND COM	MENTS (includ	ling all recommended	repairs):
SERVICING COMPANY			
Company Name:			
Address/City/State/Zip:			
Phone Number:			
Name of trained personnel performing s			
Signature of trained personnel performi			