



1333 NW Eastman Parkway, Gresham, Oregon 97030-3813
Phone 503-618-2355 • Fax 503-666-8330
GreshamOregon.gov/fire
GFD@GreshamOregon.gov

Fire Hydrant Storz Adapter Requirements

See more details at <http://www.hydrantstorz.com>.



5" Storz x 4 ½" - NH Female Rigid with Cap - HPHA50-45NHWCAP

In an effort to eliminate the need for Gresham Fire Department to carry additional fire hydrant adapters on each fire engine and to facilitate a quick water supply connection, we request that all new and existing fire hydrants have a Storz hose adapter installed on the large “steamer port.”

Private fire hydrants shall be painted Industrial Safety Red and have a 5-inch **Harrington HPHA50-45NHWCAP “Storz”** adapter installed on the 4 ½ -inch fire hydrant outlet. Fire hydrant locations shall be marked with a “BLUE REFLECTIVE” 4”x4” pavement marker at the centerline of the access road as shown above.

NOTE: While we cannot recommend a place to purchase the adapters, Gresham and Troutdale Public Works Departments purchase theirs through Ferguson Water Works, Consolidated Supply Company, HD Fowler or HD Supply. OFC 507 & NFPA 24-7.1.3